

F TECH 003 CERTIFICAT OF CONFORMITY CLINI'SAFE E

N° 15 01 009 – SAINT-GOBAIN EUROCOUSTIC Clini'Safe E / 1 Ver.0



Given by : CERA-LABO
ZAC DE TESAN
IMPASSE CARIGNANS N°10
30126 SAINT LAURENT DES ARBRES - France

to : **SAINT-GOBAIN EUROCOUSTIC**

Report : **15 01 009 – SAINT-GOBAIN EUROCOUSTIC Clini'Safe E / 1 Ver.0** written the 16th february 2015
10 12 161 – Saint Gobain Clini'Safe E / 1 Ver.0 written the 08th february 2011

Conclusions :

The tiles Clini'Safe E (600x600x15mm) give the following results:

- The particular class in normal conditions is ISO 4 according to the norm ISO 14644-1 : 1999.
- The particular class with vibrations face is ISO 4 according to the norm ISO 14644-1 : 1999.
- The Decontamination Class is CP_(0,5)5 according to the norm NFS 90-351 : 2003.
- The microbiological class according to the norm NF S 90-351 : 2013 is :

M1 / area 4	M10 / area 3
Bacillus Cereus	Klebsiella pneumoniae
Streptococcus pneumoniae	Staphylococcus aureus résistant à la méthicilline (SARM)
Aspergillus niger	
Candida albicans	

GENERAL CONCLUSIONS OF TILES CLINI'SAFE E

Classification of Clini'Safe E

Tests		Norms	Acceptance criteria	Real values	Conformity
Particular class normal conditions face		ISO 14644-1	ISO 4	ISO 4	Conform
Particular class normal conditions back		ISO 14644-1	ISO 4	ISO 4	Conform
Particular class with vibrations face		ISO 14644-1	ISO 4	ISO 4	Conform
Particle decontamination kinetics		NF S 90-351	CP _(0,5) 10	CP _(0,5) 5	Conform
Microbiology air test	<i>Bacillus cereus</i>	NF S 90-351	M10	M1	Conform
	<i>Streptococcus pneumoniae</i>	NF S 90-351	M10	M1	Conform
	<i>Staphylococcus aureus</i>	NF S 90-351	M10	M10	Conform
	<i>Klebsiella pneumoniae</i>	NF S 90-351	M10	M10	Conform
	<i>Aspergillus niger</i>	NF S 90-351	M10	M1	Conform
	<i>Candida albicans</i>	NF S 90-351	M10	M1	Conform

Remarks

- The microbiological tests as been made under Microbiological Safety Cabinet
- The completed microbiologic results are in the report :
n° 10 12 161 – Saint Gobain Clini'Safe E / 1 Ver.0 written the 08th february 2011
- The completed particular results are in the report :
n° 15 01 009 – SAINT-GOBAIN EUROCOUSTIC Clini'Safe E / 1 Ver.0 written the 16th february 2015

The Director

